

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0026:271 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-854 *Fax (978) 731-88812

DESIGN: Models MP-400 and AP-400. Non-coded; automatic or manual; local, auxiliary and proprietary protected premise service; waterflow or sprinkler supervisory services. Refer to listee's data sheet for detailed product description and operational considerations. System components:

D5200-420	Master Logic Module
D5200-427	Master Control Module
D5200-422	XA Loop Module
D5200-410	Addressable DC Indicating Module
D5200-516	Autoplex Power/Battery Charger
D5130-074-03 8	Circuit Transponder
D5200-375	Printer Module
3132-039-01	Qume Video Display
4283	Single Point Transponder
D5130-074-15	Command Receiver
5200-471	Indicating circuit Module
D5200-442	Autoplex Data Gathering Panel
5200-471	Indicating Circuit Module

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as fire alarm control unit for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: Formerly 7165-0077:112, 7165-1493:119

*Rev. 05-13-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager